

STATE OF MAINE DEPARTMENT OF TRANSPORTATION 16 STATE HOUSE STATION AUGUSTA, MAINE 04333-0016

DAVID A. COLE

June 9, 2009 Subject: **Lisbon**

Federal Project No: BR-A510(000)X

State Pin No: 015100.00 Amendment No. 2

Dear Sir/Ms:

The following question has been received:

Question: Amendment No. 1 states in the framing plan "ALL CROSS FRAMES ARE TYPE MG AS SHOWN IN MAINEDOT STANDARD DETAILS". However, also shown in the framing plan, you call for four (4) type MG and eight (8) type MH. Please clarify.

Response: The Framing Plan is Correct, 4 type (MG) and 8 type (MH) are what is needed.

Consider this information prior to submitting your bid on June 17, 2009.

Sincerely,

Scott Bickford

Contracts & Specifications Engineer

